

Date: 6/03

## **COMPRESSOR DATA SHEET Rotary Screw Compressor**

MODEL DATA - FOR COMPRESSED AIR					
1	Manufacturer: Atlas Copco Compressors, Inc.				
2	Model Number: GA110-100 W	# of Stages: 1			
	☐Air-cooled ⊠Water-cooled				
	⊠Oil-injected □Oil-free	VALUE	UNIT		
3	Rated Capacity at Full Load Operating Pressure a, e	748	acfm <sup>a, e</sup>		
4	Full Load Operating Pressure <sup>b</sup>	100	psig <sup>b</sup>		
5	Maximum Full Flow Operating Pressure <sup>c</sup>	107	psig <sup>c</sup>		
6	Drive Motor Nameplate Rating	150	hp		
7	Drive Motor Nameplate Nominal Efficiency	95.8	percent		
8	Fan Motor Nameplate Rating (if applicable)		hp		
9	Fan Motor Nameplate Nominal Efficiency		percent		
10	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	128	$kW^d$		
11	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>	17.1	kW/100 cfm <sup>e</sup>		

## NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217). ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 10) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217) as follows:

	Flow Rate d conditions	Volume Flow Rate	Specific Energy Consumption
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%
Below 0.5	Below 15	+/- 7	+/- 8
0.5 to 1.5	15 to 50	+/- 6	+/- 7
1.5 to 15	50 to 500	+/- 5	+/- 6
Above 15	Above 500	+/- 4	+/- 5

Member



This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.