COMPRESSOR DATA SHEET Rotary Screw Compressor

MODEL DATA - FOR COMPRESSED AIR					
1	Manufacturer: Sullair Corp				
2	Model Number: 1810 X Air-cooled Water-cooled	# of Stages: 1			
	X Oil-injected Oil-free	VALUE	UNIT		
3	Rated Capacity at Full Load Operating Pressure a, f	96	acfm ^{a,f}		
4	Full Load Operating Pressure ^b	150	psig ^b		
5	Maximum Full Flow Operating Pressure c	150	psig ^c		
6	Drive Motor Nameplate Rating	25	hp		
7	Drive Motor Nameplate Nominal Efficiency	91.7	percent		
8	Fan Motor Nameplate Rating (if applicable)	1	hp		
9	Fan Motor Nameplate Nominal Efficiency	82.5	percent		
10	Total Package Input Power at Zero Flow ^e	7.0	kW ^e		
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure	23.4	kW ^d		
12	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure ^g	24.38	kW/100 cfm ^g		

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217). ACFM is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 10) were measured for this data sheet. b.
- Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- Total package input power at other than reported operating points will vary with control strategy.
- Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217)

Volume Flow Rate

f, g. Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217) as follows:

	Volume Flow Rate at specified conditions		Volume Flow Rate f	Specific Energy Consumption ^g
Member	m ³ / min	ft ³ / min	%	%
MPRESSED	Below 0.5	Below 15	+/- 7	+/- 8
Č A ČÍ	0.5 to 1.5	15 to 50	+/- 6	+/- 7
ČAGĽ	1.5 to 15	50 to 500	+/- 5	+/- 6
A CAL WALLING.	Above 15	Above 500	+/- 4	+/- 5



This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.