COMPRESSOR DATA SHEET Rotary Screw Compressor

| MODEL DATA - FOR COMPRESSED AIR | | | | | |
|---------------------------------|----------------------------------------------------------------------------------------------|----------------|-------------------------|--|--|
| 1 | Manufacturer: Sullair Corp | | | | |
| | Model Number: 4509P | | | | |
| 2 | X Air-cooled Water-cooled | # of Stages: 1 | | | |
| | X Oil-injected Oil-free | VALUE | UNIT | | |
| 3 | Rated Capacity at Full Load Operating Pressure a, f | 260 | acfm ^{a,f} | | |
| 4 | Full Load Operating Pressure ^b | 125 | psig ^b | | |
| 5 | Maximum Full Flow Operating Pressure ^c | 125 | psig ^c | | |
| 6 | Drive Motor Nameplate Rating | 60 | hp | | |
| 7 | Drive Motor Nameplate Nominal Efficiency | 93.6 | percent | | |
| 8 | Fan Motor Nameplate Rating (if applicable) | 3.0 | hp | | |
| 9 | Fan Motor Nameplate Nominal Efficiency | 87.5 | percent | | |
| 10 | Total Package Input Power at Zero Flow ^e | 13.6 | kW ^e | | |
| 11 | Total Package Input Power at Rated Capacity and Full Load Operating Pressure | 54.2 | kW ^d | | |
| 12 | Specific Package Input Power at Rated Capacity and Full Load Operating Pressure ^g | 20.85 | kW/100 cfm ^g | | |

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217). ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 10) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217)
- f, g. Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217) as follows:

| Volume Flow Rate at specified conditions | | | Volume Flow Rate f | Specific Energy Consumption ^g |
|------------------------------------------|-------------------------------------------|-----------------------|--------------------|------------------------------------------|
| | $\underline{\mathbf{m}^3 / \mathbf{min}}$ | ft ³ / min | % | % |
| | Below 0.5 | Below 15 | +/- 7 | +/- 8 |
| | 0.5 to 1.5 | 15 to 50 | +/- 6 | +/- 7 |
| | 1.5 to 15 | 50 to 500 | +/- 5 | +/- 6 |
| | Above 15 | Above 500 | +/- 4 | +/- 5 |



This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.