COMPRESSOR DATA SHEET Rotary Screw Compressor

MODEL DATA - FOR COMPRESSED AIR					
1	Manufacturer: Sullair Corp				
	Model Number: 7507				
2	X Air-cooled Water-cooled	# of Stages: 1			
	X Oil-injected Oil-free	VALUE	UNIT		
3	Rated Capacity at Full Load Operating Pressure a, f	490	acfm ^{a,f}		
4	Full Load Operating Pressure ^b	100	psig ^b		
5	Maximum Full Flow Operating Pressure ^c	100	psig ^c		
6	Drive Motor Nameplate Rating	100	hp		
7	Drive Motor Nameplate Nominal Efficiency	94.1	percent		
8	Fan Motor Nameplate Rating (if applicable)	3.0	hp		
9	Fan Motor Nameplate Nominal Efficiency	87.5	percent		
10	Total Package Input Power at Zero Flow ^e	22.9	kW ^e		
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure	91.6	kW ^d		
12	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure ^g	18.69	kW/100 cfm ^g		

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217). ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 10) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217)
- f, g. Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217) as follows:

Volume Flow Rate at specified conditions		Volume Flow Rate f	Specific Energy Consumption ^g	
$\underline{\mathbf{m}^3 / \mathbf{min}}$	ft ³ / min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	



This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.