## COMPRESSOR DATA SHEET Rotary Screw Compressor

MODEL DATA - FOR COMPRESSED AIR				
1	Manufacturer: Sullair Corp			
2	Model Number: <b>7510P</b> X Air-cooled Water-cooled	# of Stages: 1		
	X Oil-injected Oil-free	VALUE	UNIT	
3	Rated Capacity at Full Load Operating Pressure a, f	418	acfm <sup>a,f</sup>	
4	Full Load Operating Pressure <sup>b</sup>	150	psig b	
5	Maximum Full Flow Operating Pressure <sup>c</sup>	150	psig <sup>c</sup>	
6	Drive Motor Nameplate Rating	100	hp	
7	Drive Motor Nameplate Nominal Efficiency	95.4	percent	
8	Fan Motor Nameplate Rating (if applicable)	3.0	hp	
9	Fan Motor Nameplate Nominal Efficiency	87.5	percent	
10	Total Package Input Power at Zero Flow <sup>e</sup>	22.1	kW <sup>e</sup>	
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	88.3	kW <sup>d</sup>	
12	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>g</sup>	21.12	kW/100 cfm <sup>g</sup>	

## NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217). ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 10) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217)
- f, g. Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217) as follows:

	Flow Rate d conditions	Volume Flow Rate f	Specific Energy Consumption <sup>g</sup>	
$\underline{\mathbf{m}^3 / \min}$	ft <sup>3</sup> / min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	





This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.

Rev: 4/1/2008

Form Number ROT 030 Rev 3 11-04